

Ariadne-Analysis

De-risking renewable energy investments

An analysis of contract design and project finance using operational wind park data

With funding from the:



Federal Ministry
of Research, Technology
and Space

Authors



» Jorge Sánchez Canales
Hertie School



» Clemens Stiewe
Hertie School



» Prof. Dr. Lion Hirth
Hertie School

Published by

Kopernikus-Projekt Ariadne
Potsdam-Institut für Klimafolgen-
forschung (PIK)
Telegrafenberg A 31
14473 Potsdam

October 2026

Quote this paper:

Jorge Sánchez Canales, Clemens Stiewe, Lion Hirth (2026): De-risking renewable energy investments. An analysis of contract design and project finance using operational wind park data. Kopernikus-Projekt Ariadne, Potsdam.

<https://doi.org/10.48485/pik.2026.36>

Corresponding Author: Jorge Sánchez Canales, j.Sanchez-Canales@hertie-school.org

This Ariadne analysis was prepared by the above-mentioned authors of the Ariadne consortium. It does not necessarily reflect the opinion of the entire Ariadne consortium or the funding agency. The content of the Ariadne publications is produced in the project independently of the Federal Ministry of Research, Technology and Space.

Content

Executive summary	3
Key findings	4
1. Introduction.....	5
2. Background: revenue risk and contract design	7
2.1 Why revenue risk matters for renewable financing.....	7
2.2 The three contract families	8
<i>Two-sided CfD</i>	<i>8</i>
<i>One-sided CfD</i>	<i>8</i>
<i>Financial CfD</i>	<i>9</i>
2.3 The ten specifications.....	9
3. Data and method in brief	11
3.1 Operational data from real wind parks.....	11
3.2 From revenue risk to the cost of electricity.....	12
4. Results.....	13
4.1 Cash-flow risk.....	13
4.2 Financing conditions and the cost of electricity.....	14
4.3 Subsidy versus de-risking	19
4.4 Project procurement	20
5. Discussion and policy implications	22
Limitations.....	24
References.....	27
Appendix A. Methods and data.....	29
A.1 Contract designs.....	29
<i>Merchant case</i>	<i>29</i>
<i>Two-sided CfD</i>	<i>29</i>
<i>One-sided CfD</i>	<i>30</i>
<i>Financial CfD</i>	<i>31</i>
A.2 Method.....	33
<i>Measuring cash-flow risk.....</i>	<i>33</i>
<i>Financial model for downside risk</i>	<i>34</i>
A.3 Data	36

Appendix B. Robustness.....	40
Appendix C. Additional results.....	41

Executive summary

Wind and solar generation requires large upfront investment but has very low running costs. As a result, the cost of clean electricity depends heavily on financing conditions, since lower borrowing costs translate directly into lower power costs. Low borrowing costs in turn require stable and predictable revenues, which volatile wholesale markets do not provide, and private markets cannot hedge price risk over the 25 to 35 year horizons that renewable projects require. For this reason, governments support renewables through long-term public contracts such as contracts-for-difference (CfDs). These contracts are usually treated as subsidies, but they serve a second function that is equally important: by reducing investors' exposure to price risk, they make projects easier to finance and lower their cost of capital.

This analysis examines how the design of such contracts affects investor risk and, through it, the cost of financing renewables. It compares three contract families: two-sided CfDs, one-sided CfDs (Germany's current "market premium"), and the recently proposed "financial CfD". The comparison draws on a dataset of hourly, turbine-level output from 63 onshore wind parks in Germany over the period 2014 to 2023, and traces the effect of each contract through a project-finance model to the final cost of electricity. The sample is an existing fleet, to which we apply today's costs. The results are informative about the ordering of contracts and the mechanisms behind it; the levels themselves should not be read as a cost forecast for new onshore wind.

Key findings

- **Most of the benefit comes from risk reduction rather than subsidy.** Long-term contracts both subsidize revenues and reduce risk, and the risk-reduction component is the larger of the two. For the best-performing designs, around 60 to 70% of the gap between market revenues and project costs is closed through lower financing costs rather than public payments. As a first-order estimate, each euro of subsidy is accompanied by 2.4 euros of lower financing costs and thus corresponds to around 3.4 euros of economic value.
- **Whether a project has a contract matters more than which contract it has.** Any well-designed long-term contract lowers the levelized cost of electricity by around 40 to 60 €/MWh, or about 30 to 45 percent, relative to selling on the market alone. The choice of contract type has a smaller effect, though it can still change the cost of electricity by up to 22 €/MWh, which remains material at system scale.
- **Stable revenues and market integration are not in conflict.** It is often assumed that protecting investors from price risk weakens their incentive to respond to market signals. The results suggest this depends on contract design rather than being unavoidable. Financial CfDs, which keep producers exposed to prices, can match or outperform conventional two-sided CfDs in reducing risk. Using an annual reference price and suspending support when prices turn negative can improve incentives and lower investor risk at the same time.
- **Contract design can substitute for higher spending.** Designs that leave the investor at the same level of profit differ by up to 22 €/MWh in what the public pays in subsidies. Improving contract design, rather than raising subsidy levels, can improve investment conditions and support the market integration of renewables. This becomes more relevant as the share of renewable generation rises.

1. Introduction

The vast majority of global power-generation investment today goes into wind and solar energy. These technologies have high upfront capital costs and low operating costs, so small changes in the cost of capital can substantially affect the levelized cost of electricity (LCOE) and the viability of a project. Yet low-cost financing requires stable and predictable revenues, which is at odds with the volatility of wholesale electricity prices and the stochastic nature of renewable generation.

To address this problem, governments across Europe have relied on policies that can be described as long-term public contracts, such as feed-in tariffs (FiTs) and contracts-for-difference (CfDs). While commonly discussed as subsidy instruments, these contracts also perform a second and equally important function: they hedge revenue risk. Revenue risk is the uncertainty in a project's income, which arises both from the price at which output is sold and from the volume produced. By reducing exposure to future electricity-price volatility, long-term contracts improve the bankability of renewable projects and enable higher leverage ratios in their financing structures.

This financial mechanism is particularly important because long-term electricity-price risk cannot be efficiently hedged in private markets. Financial electricity products are typically traded only up to five years into the future, whereas renewable project finance must plan for investment horizons of 25 to 35 years. Public support contracts therefore substitute for missing long-duration hedging markets by reallocating price risk from investors to the public sector.

Revenue stabilization, however, may come at the cost of distorted operational and investment incentives. Under fixed-price support schemes such as FiTs or simple two-sided CfDs, generators may continue producing even during periods of negative wholesale prices, because their revenues are disconnected from market conditions. Similar distortions emerge in investment decisions. A solar installation optimized solely for production volume (facing south in the northern hemisphere) may receive

the same per-unit remuneration as one better aligned with electricity demand (facing east or west). By removing price signals, highly protective contracts can therefore create welfare losses and inefficient capital allocation despite improving financing conditions.

Different contract structures provide different degrees of downside protection, upside retention, and exposure to spot prices, which implies different effects on both financing conditions and market incentives. Complexity might be a relevant factor too: a support scheme which lenders find hard to assess could be priced more conservatively. Recent literature frames renewable contract design as a trade-off between revenue stabilization and efficient market integration. Schlecht et al. (2024) have proposed a “financial CfD” that aims to resolve the trade-off by keeping producers exposed to market prices, but they did not assess its de-risking performance. That is the empirical question this report addresses.

The analysis uses real operational data rather than weather simulations. We draw on a unique dataset from a major German operator, covering hourly electricity production (both realized and potential) from more than 60 onshore wind parks. This matters because, as practitioners often argue, real-world production restrictions (wildlife protection, shadow and noise limits near settlements, localized grid bottlenecks, or turbine downtime) render simulated data unreliable when it comes to risk profiles, since they might correlate systematically with price patterns. These frictions are included in our revenue analysis, so the comparison of contracts reflects the risk profiles that real wind projects actually face.

Sections 4.1 and 4.2 focus on cash-flow risk, the year-to-year variation in revenues minus operating costs, rather than on the level of revenue; Sections 4.3 and 4.4 then turn to the level of support. Our findings show that well-designed financial CfDs reduce cash-flow risk more than current one-sided designs and, depending on the specification, can outperform the standard two-sided CfD as well. The commonly assumed trade-off between revenue stabilization and market integration can

therefore be resolved through contract design. For two-sided CfDs, adding the rule that generators may not get compensation during negative hours does not increase their risk exposure, because those hours fell mostly in windy periods; Section 5 discusses whether this holds as they become more frequent.

2. Background: revenue risk and contract design

2.1 Why revenue risk matters for renewable financing

High cash-flow volatility reduces the internal funds available to a firm and, at the same time, its access to external financing, raising borrowing costs and the likelihood of financial distress (Li et al., 2023). Several empirical finance studies support this link between volatility and credit spreads, often using the coefficient of variation (CoV) of annual revenues as a normalized measure of cash-flow volatility (Augustin et al., 2025; Minton et al., 2002; Minton & Schrand, 1999; Molina Manzano, 2005; Tang & Yan, 2010). At the same time, project-finance practice and credit-risk models emphasize downside risk rather than symmetric variability, since defaults and covenant breaches are triggered by low-cash-flow states rather than by high volatility as such. This report uses both lenses: the coefficient of variation to summarize overall risk, and a project-finance model focused on the worst annual outcome to capture downside risk.

Wind projects are capital-intensive, which makes them highly sensitive to fluctuations in cash flows. For projects operating in the market, three sources of uncertainty affect the stability of these cash flows: market (price) risk, weather-related (volume) risk, and grid-related curtailment (volume) risk (Gatzert & Kosub, 2016). Public support schemes primarily target price and curtailment risk, leaving weather-driven volume risk largely unmanaged; but they also introduce risks of their own, such as volume risk in contracts where support is suspended in negative-price hours.

2.2 The three contract families

Against a merchant benchmark (a generator with no long-term contract, selling all its output in the day-ahead auction), we consider three families of long-term public contract. Formal definitions are given in Appendix A.1.

Two-sided CfD

Introduced in the UK electricity-market reform of 2014, a two-sided CfD tops up market income by comparing a reference price to a pre-agreed strike price. The government pays the generator when the reference price falls below the strike, and the generator pays the government when it exceeds the strike. Where the reference is the spot price of the same settlement period, this removes price risk entirely. Its weakness is the classic “produce-and-forget” incentive: with a fixed price, the investor is rewarded for volume regardless of when, and therefore how valuably, the electricity is produced. We model three variants: an hourly reference price; an annual reference price (the market value of onshore wind); and an annual reference that also suspends support when spot prices turn negative, the variant closest to the European Commission's guidance (European Commission, 2025).

One-sided CfD

Under a one-sided CfD (the “market premium” model used in Germany since 2012, and also in the Netherlands and Italy), the government tops up revenues when prices fall below the strike, but the generator never pays money back. Price risk is therefore only partly mitigated: the contract behaves like no support when market prices are always high, and like a two-sided CfD when they are always low. We model the same three reference-price variants as for the two-sided CfD.

Financial CfD

The financial CfD, proposed by Schlecht et al. (2024), replaces production-based payments with a fixed-for-floating swap. The government pays the generator a fixed, capacity-based amount, and the generator pays back a variable amount tied to market prices and an external reference generation profile rather than to its own output. Because payments are “injection-independent”, the generator always has an incentive to stop producing when prices are negative, so market signals are preserved. The remaining risk stems only from deviations of a park’s actual output from the reference profile (“basis risk”). Two parameters define the contract: a reference profile (here, the national hourly capacity factor of onshore wind) and a contract factor that scales the contracted capacity. We model four specifications that differ in how the contract factor is set (baseline, fleet-optimal, technology-adjusted, and park-optimal), described in the table below and in Appendix A.1.

2.3 The ten specifications

The analysis compares ten contract specifications in total, three per family for the two- and one-sided CfDs and four for the financial CfD, against the merchant baseline. Table 1 lists them and defines the labels used in the figures that follow.

Label (in figures)	Family	Reference / factor	Description
Merchant	Baseline	No contract	No long-term contract; the generator sells all output on the spot market. Reference case.
2-CfD Hourly	Two-sided	Hourly spot price	Guarantees a fixed per-unit price and removes price risk fully; produces “produce-and-forget” incentives.

2-CfD Annual	Two-sided	Annual market value of onshore wind	Hedges price risk while keeping some spot-price incentive; introduces limited basis risk.
2-CfD Annual (curtailed)	Two-sided	Annual market value of onshore wind	As above, but support is suspended when spot prices are negative (closest to the European Commission's guidance).
1-CfD Hourly	One-sided	Hourly spot price	Top-up only, with no clawback; partial price-risk mitigation.
1-CfD Annual	One-sided	Annual market value of onshore wind	Top-up only, with an annual reference price.
1-CfD Annual (curtailed)	One-sided	Annual market value of onshore wind	Top-up only, with support suspended when spot prices are negative.
F-CfD (baseline)	Financial	Contract factor = 1	Capacity-based swap on the full installed capacity; injection-independent.
F-CfD (fleet-optimal)	Financial	Common factor, cost-minimizing	A single contract factor for all parks, chosen to minimize average investment cost (average downside risk).
F-CfD (tech-adjusted)	Financial	Factor $\propto$ expected output	Park-specific factor proportional to expected production, which limits adverse selection.
F-CfD (park-optimal)	Financial	Factor minimizing each LCOE	Park-specific factor chosen separately for each project to minimize its cost of electricity.

Table 1. The ten contract specifications (plus the merchant baseline) compared in this report. The labels in the first column are those used on the horizontal axis of Figures 1 to 5. Full definitions are given in Appendix A.1.

3. Data and method in brief

3.1 Operational data from real wind parks

A key strength of this analysis is the use of real production data from operational turbines rather than simulated or synthetic profiles. Real-world output is shaped by constraints that are hard to model, such as turbine maintenance, curtailment for environmental permitting (bird or bat protection), noise and light limits, and local grid restrictions. These frictions may correlate systematically with price patterns, affecting the risk profile of investment projects. Observing the realized feed-in lets us capture these frictions directly and produce more realistic assessments of revenue volatility. The fact that the data includes a large number of projects also allows us to capture heterogeneity that simulations usually miss: not just different weather and price years, but differences in site quality and turbine technology.

The core dataset covers turbine-level production for 381 turbines across 93 German wind parks. After excluding parks that entered operation after 2014 and those with missing or persistently very low output, the estimation sample contains 268 turbines across 63 wind parks, with a combined capacity of about 510 MW and an average capacity factor of 18 percent, continuously observed over the ten years from 2014 to 2023. That window spans major market events, such as the Covid-19 period and the 2022–2023 energy crisis, as well as a wide range of weather years. Each observed year is weighted equally. The simulations combine this production data with hourly electricity prices (ENTSO-E), national feed-in profiles (Netztransparenz), and installed-capacity data (Open Power System Data and ENTSO-E).

Appendix A describes the dataset in more detail: the parks are concentrated in north-eastern Germany and are operated by a single company (Figure A1); this concentration limits how far the sample speaks to siting conditions elsewhere, although the spread of production profiles within it is wide (Figure A2).

3.2 From revenue risk to the cost of electricity

For each contract and each park, we simulate hourly revenues and aggregate them to annual figures. We then summarize cash-flow risk with the coefficient of variation of annual revenues, a standard normalized measure that allows comparison across parks of different sizes and production profiles.

Because investors and lenders ultimately care about financing costs, we then feed the simulated revenue distributions into a stylized project-finance model (see the full model in Appendix A.2). In line with project-finance practice, lenders size debt on low-percentile cash flows rather than average volatility: our model requires debt service to be covered in every simulated year (a debt-service coverage ratio of at least one in all states). Contracts that raise the minimum annual cash flow therefore permit more debt, which is cheaper than equity, and therefore lower the weighted average cost of capital (WACC) and, in turn, the levelized cost of electricity (LCOE). Assuming competitive auctions in which projects just break even, the model yields an implied LCOE for each contract and park. In other words, the LCOE and support levels are endogenous and both change by park and contract such that each project just breaks even. The key cost and financing assumptions are summarized in Table 2.

Parameter	Value	Source	Note
Investment cost	1,500 €/kW	IRENA (2024)	
O&M cost	50 €/kW·a	IRENA (2024)	Includes land rents (a large share)
Cost of debt	1.15 %	Đukan et al. (2025)	
Cost of equity	10.0 %	Đukan et al. (2025)	
Project lifetime	30 years	Own assumption	

Table 2. Cost and lifetime assumptions used in the financial model. O&M costs include the land rents investors pay each year, which are a substantial share of the figure; technical O&M alone is considerably lower.

4. Results

This section presents the empirical de-risking performance of the different contract designs. Using the simulated annual revenue streams, we first compare cash-flow risk across contracts using the coefficient of variation. We then examine the leverage and WACC outcomes of the financial model and the resulting reductions in LCOE. Next, we decompose the effect of each contract into a subsidy component and a de-risking component, show how the effect differs between parks, and estimate what each design costs the public when projects are procured in order of cost. The methods behind these results are detailed in Appendix A.

4.1 Cash-flow risk

Figure 1 summarizes cash-flow risk across wind parks under each contract specification, measured by the coefficient of variation of annual revenues. Three findings stand out. Wind parks under the merchant baseline exhibit very high CoVs, confirming that merchant exposure alone provides insufficient risk management for project finance. All CfD designs substantially reduce cash-flow risk relative to the merchant case, but to different degrees: two-sided and financial CfDs consistently deliver the lowest CoV values, while one-sided CfDs leave significantly more risk with investors. The difference lies in the upside: a two-sided CfD pays back revenue above the strike, whereas a one-sided CfD lets the generator keep it, as in the high-price years of the 2022–2023 energy crisis. Because strike prices are set so that each project just breaks even, they differ across contracts and parks, and a generator that keeps the upside needs a strike below its LCOE, which also lowers the floor that protects it in low-price years. Finally, two-sided CfDs achieve both very low CoVs and narrow distributions, whereas the lowest overall cash-flow risk is reached by park-optimal financial CfDs, even though these are optimized for downside risk rather than for the coefficient of variation.




Figure 1. Average coefficient of variation of annual revenues across contract specifications. Bars show the average CoV for a given contract; whiskers indicate the central 80% (10–90%) of the distribution.

A second insight from Figure 1 is that using an annual reference price combined with curtailing generation during negative-price hours reduces cash-flow risk for both two-sided and one-sided CfDs, compared with hourly referencing, despite introducing some basis risk. The reason is that an annual reference moves with the price the park earns in the market. Annual revenue becomes the output multiplied by the strike plus the park's own capture price minus the market value of onshore wind (see Equation 2 in Appendix A). The price level cancels, and what remains is the park's basis against the fleet, which is less favorable in high-output years and so partly offsets volume risk. Using the market value of wind therefore appears preferable, since it leads to both better incentives and lower risk for investors.

4.2 Financing conditions and the cost of electricity

Feeding these cash-flow patterns into the financial model (see Appendix A.2), we calculate the equilibrium leverage ratios and WACC under each specification (Figure

2). Under the merchant baseline, most parks cannot afford any debt, because at least one year's revenues would be insufficient to cover any debt service. This reflects the mechanics of the model, which links the minimum annual cash flow to risk-free leverage, together with the significant land rents that must be paid and the presence of several very low-price years in the sample, including the 2020 Covid-19 period. For all CfD contracts, leverage generally falls within the 40 to 90% range observed for real-world renewable projects under long-term contracts (Dukan et al., 2019; Roth et al., 2021). Two-sided CfDs tend to lower the cost of capital more than one-sided CfDs. Among financial CfDs, specifications with endogenous contract factors achieve the highest leverage, while those that set the contract factor exogenously perform somewhat worse than two-sided CfDs.




Figure 2. Financial indicators across wind parks under each contract type. Blue bars show the average leverage ratio; whiskers indicate the central 80% (10–90%) of the distribution. Red dots show the average WACC implied by that leverage, based on the assumptions in Table 2.

From the WACC we calculate the implied LCOE under each specification (Figure 3). All CfDs reduce LCOE relative to the merchant case by lowering financing costs (the de-

risking effect), but the magnitude differs markedly across designs. Average LCOE reductions range between 40 and 60 €/MWh under our cost assumptions, which means that 30 to 45% of the LCOE can be removed through the better financing conditions the contracts make affordable. Two-sided CfDs deliver the largest reductions among the classical designs, reflecting their complete removal of price risk. One-sided CfDs also reduce LCOE, but less strongly, consistent with their weaker risk mitigation. Financial CfDs perform similarly to one-sided or two-sided CfDs depending on the contract factor, with optimal factors yielding the lowest LCOEs of all contracts.




Figure 3. LCOE levels across wind parks under each contract type. Bars show the average LCOE; whiskers indicate the central 80% (10–90%) of the distribution.

The figure shows that financial CfDs with well-chosen parameters can match or outperform two-sided CfDs in terms of both risk reduction and financing conditions. The reason is that the financial CfD also (partially) hedges volume risk. A production-based CfD pays per MWh produced, so a low-wind year still means low revenue; under the financial CfD, the generator's payment back follows the national wind index, so in

a low-wind year the park produces less but also pays back less. The common component of price and volume risk cancels, and what remains is the part of the park's output that deviates from the reference profile. The contract factor works as a hedge ratio, which is why park-specific factors, matched to how closely each park tracks the index, outperform a single fleet-wide factor.

Taken together, these results show that having any form of long-term public support plays a major role in the ability to finance renewable investment, whereas the specific form of the contract plays a smaller role. That smaller effect is still significant: differences of around 22 €/MWh between designs are material at system scale. Since the electricity is worth the same in the market regardless of the contract, a difference in LCOE between two designs is a difference in the support the public pays for the same project. The difference of 22 €/MWh between the cheapest and the most expensive design in Figure 3 is therefore the gap in public cost, and it arises entirely from differences in financing costs under each contract. Weighted by output the same gap is 16 €/MWh, which for the 510 MW in this sample is a difference of between 15 and 28 million euros a year.

The size of the de-risking effect is not the same for every park. A useful way to separate projects is by whether a project's own capture price is higher than the market value of onshore wind over the sample period (56.9 €/MWh), that is, whether its output is higher-quality than average. Four of our 63 parks earn more under market prices than they would facing a flat price at the level of the market average, and 59 earn less. The distribution is shown in Figure A3: most parks sit a little below the national mean, as one might expect of an aging fleet, and two sit well above it.

Figure 4 reports the difference in the proportional reduction in the cost of electricity between the two groups by contract. Every contract design that pays per unit of output has a de-risking effect tilted towards the high-volume parks. Where remuneration is, or approaches, a fixed amount per MWh, the annual cash flow that sizes the debt is linear in the park's annual production, so the contract de-risks in proportion to how

stable that production is, and the value of the output does not enter. The financial CfD is the only family whose payment is decoupled from the park's own output. Those specifications with exogenous contract factors (baseline and technology-adjusted) are the only designs that proportionally favor the high-value parks. That is the consequence of an oversized hedge: the claw-back is calculated on full installed capacity against a national reference profile, and the parks whose market income per MW falls furthest short of that reference are over-hedged the most. Endogenizing the factor removes the mis-sizing and the difference between the groups falls below 1.5 percentage points. The high-value group contains four parks, so the size of these differences should be read with care. Fitting the same relationship across all 63 parks instead of splitting them gives smaller differences (under five percentage points in either direction) but the same sign for every design.




Figure 4. Difference in the proportional reduction in the cost of electricity between the four parks whose capture price exceeds the market value of onshore wind over the sample period and the 59 that fall below it (Figure A3). Bars to the right of zero mark designs that de-risk high-value parks more; bars to the left mark designs that favor parks whose revenue comes from volume. Unweighted means across parks.

4.3 Subsidy versus de-risking

As noted in the introduction, long-term public contracts simultaneously subsidize revenues and hedge investors against cash-flow risk. We disentangle the two by decomposing how each contract closes the “merchant gap”, defined as the difference between the LCOE and the capture price a project would earn under merchant exposure. Consider a project with a capture price of 30 €/MWh and an LCOE of 90 €/MWh: the merchant gap is 60 €/MWh. If a contract reduces costs to 50 €/MWh by enabling low-cost financing, then 40 €/MWh of the gap is closed through risk reduction and the remaining 20 €/MWh must come from an outright subsidy. In this example, two-thirds of the support effect arises from de-risking. This is a good deal for public finance, because only the subsidy strains public budgets.




Figure 5. Decomposition of how each contract closes the merchant gap, split into a subsidy effect (a higher average price at which investors sell their electricity) and a risk-reduction effect (a lower LCOE through better financing conditions).

The results are shown in Figure 5. The merchant gap to be closed for a project to be viable is the same regardless of contract, on average 87 €/MWh, but contracts differ in the relative size of their hedge and subsidy components. For two-sided CfDs, de-risking amounts to around 52 €/MWh, and the remaining 35 €/MWh comes from higher effective prices via the subsidy. For the fleet-optimal financial CfD, the hedging effect makes up 57 €/MWh, and for the park-optimal financial CfD it reaches around 62 €/MWh, with only 25 €/MWh of subsidy. For the park-optimal financial CfD, every 1 € of subsidy is accompanied by 2.4 € of lower financing costs, for a total of 3.4 € in social value of public funds thus spent; for the two-sided CfD these figures are 1.5 and 2.5 € respectively.

Rather than the exact figure of the return on spent public funds, the relevant takeaway is that contract design can leverage public funds substantially by targeting cash-flow risk rather than price levels alone. Considering this decomposition beyond our sample, we can see that the two components rest on different features. The de-risking effect works through debt capacity, which the model derives from the worst year observed. The subsidy component works through the merchant gap, which depends on the average capture price. The sample spans an exceptional price episode from 2021 to 2023, which raises the average capture price and reduces the need for a subsidy. This does not apply to the worst year for two-sided and merchant contracts, such that their de-risking estimates are likely robust; for the financial CfD, however, the crisis years are often the worst years, so the de-risking estimate for that contract is, if anything, conservative.

4.4 Project procurement

Section 4.3 reported what each design costs the public when every park in the sample is financed. That is not necessarily how procurement works. An auction awards

contracts to the cheapest projects and leaves the rest unbuilt, so what the public pays depends on how far down the merit order procurement reaches.

Figure 6 ranks the parks by their cost under each contract, procures the cheapest first, and reports the average net public support for the volume procured. Here, each winner receives its own break-even remuneration. Bidding at true cost is the dominant strategy under uniform pricing, as in the day-ahead market, but not under the pay-as-bid rule German auctions use, where a winner has an incentive to bid above its cost. The figure is therefore systematically lower than public costs under either rule. Table C1 in Appendix C holds our estimate of inframarginal winner rents, assuming the cheapest 20 projects under each design are procured. The curves rise throughout, because procuring more means reaching further down the merit order.




Figure 6. Average net public support against the capacity procured, when projects are awarded contracts in order of cost and each winner receives its own break-even remuneration. Energy-weighted, so the value at each point is the public cost per MWh of the volume procured.

At small volumes (less than 100 to 150 MW in our sample) net public support is negative under most designs. With only these projects, over 2014–2023, the state

would have received more in claw-backs than it paid out. Rather than being subsidized, these projects benefit from the debt capacity a long-term contract provides, and over this price history the contract pays for itself. The one-sided CfD is the exception, constituting a net cost at every volume, because it never claws back.

The ranking of designs is stable across volumes, with one exception. The financial CfD with a contract factor of one crosses the others: at 10 MW it is close to the two-sided CfD, and at full procurement it is the most expensive design. A hedge of that size is adequate for a small and homogeneous set of good projects and expensive once procurement reaches a heterogeneous fleet.

The one-sided designs move the other way. They are relatively priciest at the lowest volumes (where it could matter more for new procurement), and become relatively cheaper as procurement reaches more expensive projects: the strike rises, the top-up binds in more years, and the contract behaves more like a two-sided CfD.

5. Discussion and policy implications

Using real hourly production data from 63 wind parks over ten years, this report compares how three families of long-term public contracts mitigate investment risk for onshore wind, and how that risk reduction feeds through to the cost of electricity. We simulate project revenues under two-sided CfDs, one-sided CfDs, and financial CfDs, and quantify cash-flow risk using both the coefficient of variation of annual revenues and a project-finance model focused on downside risk. In that model, debt capacity is determined by low-revenue states, with debt service required to be covered in all simulated years and equity bearing the residual risk. Under competitive auctions, contract levels are set so that both the debt and equity constraints bind, which yields an implied LCOE for each design.

Financial CfDs can perform as well as, if not better than, one-sided and two-sided CfDs in reducing cash-flow risk and lowering LCOE, while preserving more exposure to

market signals. When contract parameters are calibrated appropriately, these improvements do not require higher public spending. A contract factor of one over-hedges most parks and makes the financial CfD the most expensive design, whereas choosing it per park makes it the cheapest. Park-specific factors may not be available in a central auction, since the quality of an asset is often unknown to the auctioneer. One way to reconcile the two is to let bidders choose their own contracted capacity and rank them by expected net support per MWh, in the spirit of the German reference-yield model, which already scales the award by site quality. Well-calibrated financial CfDs relax the classic trade-off between risk mitigation and market integration: they substantially reduce investor risk without fully insulating producers from market dynamics. The same can be argued for two-sided CfDs with annual reference profiles and curtailment during negative-price hours.

The decomposition of the merchant gap shows that a large share of the value these contracts create can come from de-risking rather than from pure price support. For the most effective designs in our sample, roughly 60 to 70% of the gap is closed through lower financing costs, with the remainder due to higher effective prices. Given the capital intensity of renewable investment, carefully designed contracts can therefore deliver substantially cheaper clean electricity for a given level of public expenditure, without necessarily implying excessive returns for generators. This holds especially where support is allocated through competitive auctions, in which lower risk is often associated with lower equity returns (Đukan et al., 2019). Where auctions are undersubscribed and awards settle near the ceiling price rather than at break-even, the savings in public cost shown in Sections 4.3 and 4.4 do not materialize.

These findings indicate that contract design, rather than more public spending in the form of higher subsidy levels, can simultaneously improve investment conditions and support the market integration of renewables. As renewable penetration continues to increase, aligning risk mitigation with efficient dispatch will be critical to sustaining the energy transition. Any change of support scheme creates winners and losers.

Under a financial CfD this is the intended effect rather than a side effect: the generator keeps its full market income, so projects gain when they produce at times when electricity is valuable and lose when they produce mainly when it is abundant. This redistribution is the price signal that steers siting and turbine choice towards more valuable output, which a contract paying per MWh produced weakens.

For a scheme designed now, we make two practical recommendations. First, for production-based contracts, reference the contract to the annual market value of onshore wind rather than to the spot price of the settlement period and suspend support in negative-price hours: on this sample that combination lowers both investor risk and public cost. And second, if a financial CfD is used, the contract factor can be set in different ways: leaving it at one gives tight incentives that promote high-value investment and stays cheap for a small set of assets, while setting it per project is the cheapest option at any volume procured, at the same return to the investor, though harder to implement.

Limitations

Several limitations should be borne in mind. These pertain to the model, the sample and our assumptions. First, because the analysis relies on historical data rather than a full market model, it does not capture the feedback from contract-specific dispatch incentives to market prices. During most of the sample period, German onshore wind was remunerated through feed-in tariffs or premiums, which encouraged production even at strongly negative prices. Under schemes with stronger price exposure (annual reference prices or financial CfDs), some of this output would likely have been withheld, raising prices in those hours and potentially changing contract performance. Similarly, under different support schemes, the set of projects procured would be different (Figure 6), such that the price path would be different. Finally, the same caveat applies to the suspension of support at negative prices. This is relevant because

in our sample, negative prices occurred mostly in high-wind periods, with a countercyclical effect; but as solar capacity grows and more negative prices are driven by solar rather than wind generation, the risk impact of suspended payments could change. The results should therefore be read as partial-equilibrium revenue outcomes for given price and investment paths.

A second limitation is that cost and financing assumptions are homogeneous across parks of different vintages and sites, which affects absolute LCOE levels; a sensitivity analysis (Appendix B) shows that the ranking of contracts is nonetheless robust across a wide range of cost assumptions. The financial CfD is implemented with a single national reference profile; location-specific benchmarks would change basis risk but not the core requirement that benchmarks stay exogenous enough to preserve dispatch incentives. Finally, each park is treated as a standalone investment, whereas investors often hold diversified portfolios that could dampen project-specific volatility.

Third, regarding our assumptions, the debt-service constraint we impose is unusual in its shape: full coverage in every observed year, at a coverage ratio of one. Project finance normally requires a ratio of 1.2 to 1.3, but against a modeled downside case rather than against every historical year. Our rule is therefore more lenient in level and stricter in the states it must hold in. Overall, our model seems more likely to overstate debt capacity and understate the cost of electricity, but this counters the fact that we apply today's (higher) investment and land costs to a fleet built up to two decades ago. Our model does also not account for contract complexity: a production-based CfD settles on metered output and is easily explained; the financial CfD settles a swap against an external profile, and a lender unfamiliar with it might price the resulting risk more conservatively than our ex-post analysis shows.

One feature of our sample points in a useful direction. The fleet we observe was built under volume-based remuneration, and it comes as no surprise that only four of 63 parks earn more under market prices than at a flat price equal to the market value of onshore wind (Figure A3). Any study using real operational data will meet a similar

problem, because the fleet that exists was built under the contracts that existed. Our sample sits below the average, but we can still learn from it what a more diverse or higher-value fleet would do to the comparison. Two-sided CfDs de-risk volume-driven parks more; financial CfDs with endogenous factors are close to neutral between the two; the unsized financial CfD favors high-value parks. The gap between the families would therefore widen rather than narrow in the kind of fleet that new procurement is meant to bring forward. Read the other way, our sample may be an unfavorable case for the financial CfD, and its sample-calibrated variants still perform at least as well as the alternatives.

References

- Alcorta, P., Espinosa, M. P., & Pizarro-Irizar, C. (2024). Right and Duty: Investment Risk Under Different Renewable Energy Support Policies. *Environmental and Resource Economics*, 87(12), 3163–3204.
- Augustin, P., Cong, L. F., Lopez A., R., & Tédongap, R. (2025). Downside Risk and the Cross-section of Corporate Bond Returns (SSRN Scholarly Paper No. 3710533). Social Science Research Network.
- Barquín Gil, S., Rodilla Rodríguez, P., Cossent Arín, R., & Battle López, C. (2017). Obtaining best value for money in RES auctions: A capacity-based with an embedded menu of contracts approach. Working Paper IIT.
- Chebotareva, G., Strielkowski, W., & Streimikiene, D. (2020). Risk assessment in renewable energy projects: A case of Russia. *Journal of Cleaner Production*, 269, 122110.
- Đukan, M., Keles, D., & Kitzing, L. (2025). The Impact of Two-Sided Contracts for Difference on Debt Sizing for Offshore Wind Farms. *The Energy Journal*, 46(5), 145–188.
- Đukan, M., Kitzing, L., Brückmann, R., Jimeno, M., Wigand, F., Kielichowska, I., Klessmann, C., & Breitschopf, B. (2019). Effects of auctions on financing conditions for renewable energy.
- ENTSO-E. (2024). Position Paper on Sustainable Contracts for Difference Design.
- European Commission. (2024, April 30). State aid to support construction of nuclear power plant.
- European Commission. (2025, December 19). Commission guidance on the design of two-way contracts for difference. *Official Journal of the European Union*, (C/2025/6701).
- Fabra, N., & Llobet, G. (2025). Designing Contracts for the Energy Transition.
- Falconett, I., & Nagasaka, K. (2010). Comparative analysis of support mechanisms for renewable energy technologies using probability distributions. *Renewable Energy*, 35(6), 1135–1144.
- Favre, K., & Roques, F. (2023). Designing Contracts for Difference for the EU Power Markets: Trade-off between Incentives and Risks. 2023 19th International Conference on the European Energy Market (EEM), 1–6.
- Gatzert, N., & Kosub, T. (2016). Risks and risk management of renewable energy projects: The case of onshore and offshore wind parks. *Renewable and Sustainable Energy Reviews*, 60, 982–998.
- Huntington, S. C., Rodilla Rodríguez, P., Herrero, I., & Battle López, C. (2017). Revisiting support policies for RES-E adulthood: Towards market compatible schemes. *Energy Policy*, 104, 474–483.
- IRENA. (2024). Renewable Power Generation Costs. International Renewable Energy Agency.
- Johanndeiter, S., Helistö, N., & Bertsch, V. (2025). Does the difference make a difference? Evaluating Contracts for Difference design in a fully decarbonised European electricity market. *Resource and Energy Economics*, 101495.
- Leblanc, C. (2023). Microeconomic analysis of subsidy mechanisms for power generation from wind and solar sources [PhD Thesis, École des Ponts ParisTech].
- Li, X., Gupta, J., Bu, Z., & Kannohtira, C. G. (2023). Effect of cash flow risk on corporate failures, and the moderating role of earnings management and abnormal compensation. *International Review of Financial Analysis*, 89, 102762.

- Minton, B. A., & Schrand, C. (1999). The impact of cash flow volatility on discretionary investment and the costs of debt and equity financing. *Journal of Financial Economics*, 54(3), 423–460.
- Minton, B. A., Schrand, C. M., & Walther, B. R. (2002). The role of volatility in forecasting. *Review of Accounting Studies*, 7(2–3), 195–215.
- Molina Manzano, C. (2005). Are Firms Underleveraged? An Examination of the Effect of Leverage on Default Probabilities. *Journal of Finance*, 60(3), 1427–1459.
- Newbery, D. (2023). Efficient Renewable Electricity Support: Designing an Incentive-compatible Support Scheme. *The Energy Journal*, 44(3).
- Roth, A., Brückmann, R., Jimeno, M., Đukan, M., Kitzing, L., Breitschopf, B., Alexander-Haw, A., & Blanco, A. L. A. (2021). Renewable energy financing conditions in Europe: Survey and impact analysis. *Aures*.
- Schlecht, I., Maurer, C., & Hirth, L. (2024). Financial contracts for differences: The problems with conventional CfDs in electricity markets and how forward contracts can help solve them. *Energy Policy*, 186, 113981.
- Staffell, I., & Pfenninger, S. (2018). The increasing impact of weather on electricity supply and demand. *Energy*, 145, 65–78.
- Tang, D. Y., & Yan, H. (2010). Market conditions, default risk and credit spreads. *Journal of Banking & Finance*, 34(4), 743–753.

Appendix A. Methods and data

This appendix details the contract specifications, the measure of cash-flow risk, the project-finance model, and the data used.

A.1 Contract designs

We assess ten different contract specifications in total, corresponding to three groups: two-sided CfDs, one-sided CfDs, and financial CfDs. As a benchmark, we use the merchant case (no long-term contract).

Merchant case

As “merchant case” M we describe the situation that a generator has no long-term contract and receives revenue only from selling output in the day-ahead market. The revenue R of a generator i for an hour t is defined as the product of the generation $q_{i,t}$ and the electricity spot price p_t . For simplicity, we assume that for each hour there is a unique spot price, which can be interpreted as generators selling their production only on the day-ahead auction of the wholesale market. In other words, we ignore intraday markets and imbalance settlement, which in practice do affect a project's cash flow; since none of the contracts we compare alters the obligation to balance, including them would probably raise measured risk under all designs. The revenue over the course of year y is given by

$$R_{i,y}^M = \sum_{t=1}^{t=T} q_{i,t} p_t, \quad (1)$$

where the set $t = \{1, T\}$ refers to all hours in year y .

Two-sided CfD

We denote the two-sided CfD as $2CfD$ in equations. We decompose hourly revenue into market income and CfD payments. For a given hour t , the total revenue of a generator i is defined as the product of generation $q_{i,t}$ and the sum of the realized spot price (p_t) and the CfD payment, which depends on the difference between the strike price (S) and the reference price (p_t^{ref}). The total annual revenue is

$$R_{i,y}^{2CfD} = \sum_{t=1}^{t=T} q_{i,t} p_t + q_{i,t} (S - p_t^{ref}). \quad (2)$$

Under a classical “UK-style” two-sided CfD, the reference price equals the hourly spot price at which generators sell their electricity in the spot market ($p_t^{ref} = p_t$), such that the CfD payment simply offsets

deviations of p_t from the strike. This case constitutes our first specification. In this case there is only one source of variation, the *volume risk* of production $q_{i,t}$. The price risk disappears since the strike price remains the same for the duration of the contract. This contract leads to the so-called “produce-and-forget” incentives: the investor has only an incentive to maximize the volume of production $q_{i,t}$ regardless of the economic value of the energy produced (which depends on the time when the electricity was produced).

Because this variant of the contract is rarely considered by policymakers nowadays, we model a second specification using an annual reference price. The reference price is the market value of onshore wind, defined as the volume-weighted average price of onshore-wind-generated electricity across all wind parks in the country:

$$\bar{p}_y^w = \frac{\sum_1^T (Q_t^w p_t)}{\sum_1^T Q_t^w}, \quad (3)$$

where Q_t^w refers to the market wide generation of onshore wind power. When a reference price other than the hourly spot market is used, different incentives emerge. Because the reference is exogenous to a single plant but correlated with its output, it provides an imperfect but good hedge against price risk while keeping some of the wholesale price incentives alive. In hours when the spot price falls significantly below zero and the strike is not high enough to justify production ($S + p_t - p_t^{ref} \leq 0$), we assume that generators curtail all production ($q_{i,t} = 0$) to avoid losses.

Our third and last specification of the two-sided CfD suspends payments from governments to generators whenever spot prices turn negative. This incentivizes generators to always curtail their production at negative prices ($p_t \leq 0$). The European Commission's current guidance points in this direction. It prefers a two-sided CfD, that is, with some payments from the generator to the government, but it does not endorse the standard version. Instead, it requires that generators retain their incentives to bid into the day-ahead, intraday, balancing and ancillary-services markets, and recommends quarterly or annual rather than settlement-period reference prices (European Commission, 2025).

In sum, we assess three variants of the two-sided CfD: an hourly reference price, an annual reference price, and annual reference in addition to suspension during negative prices. In this order, incentives improve but hedging quality is suspected to deteriorate.

One-sided CfD

For the one-sided CfD (1CfD), we use the same decomposition into market income and CfD payments as above. The overall annual revenue a generator producing electricity under a one-sided CfD is

$$R_{i,y}^{1CfD} = \sum_{t=1}^{t=T} q_{i,t} p_t + q_{i,t} \cdot \max(S - p_t^{ref}, 0). \quad (4)$$

Under this contract, the price risk is only partially mitigated. In the extreme case where $p_t^{ref} \geq S$ for all t , the contract is identical to that of having no support, whereas in the opposite extreme case where $p_t^{ref} \leq S$ for all t , the contract is identical to that of a two-sided CfD.

As with the two-sided CfD, we consider three specifications:

- (i) using the hourly spot price p_t as the reference price p_t^{ref} ;
- (ii) using the annual market value of wind $\bar{V}_y^W$ (defined above in equation 3) as the reference price p_t^{ref} ; and
- (iii) using the annual market value of wind $\bar{V}_y^W$ while suspending payments when spot prices are negative.

As above, we assume generators always dispatch according to economic incentives, i.e. curtail if total revenue is negative.

Financial CfD

The third major design we consider is the financial CfD, as proposed by Schlecht et al. (2024). This contract consists of two separate hourly payments between generator and government: a fixed (lump-sum) payment from the government to the generator F in exchange for a variable (floating) payment from the generator to the government that reflects market conditions V_t . Effectively, the contract is a fixed-for-floating swap.

Unlike conventional CfDs, this contract is not tied to asset outputs, hence it has been described as “injection-independent” (as opposed to “production-based”). The Commission also contemplates this as a direction for future contract design (European Commission, 2025). For a generator with installed capacity K_i (in MW), the contracted capacity k_i can be defined as:

$$k_i = \alpha \times K_i, \quad (5)$$

Where $\alpha > 0$ is the contract factor.

At each hour t , the three revenue components are:

- The market income of the generator:

$$M_{i,t} = q_{i,t} p_t, \quad (6)$$

- The lump-sum payment from government to generator:

$$F = k_i A, \quad (7)$$

where A is the payment in €/MW agreed in the contract. It is somewhat analogous to the strike price S in production-based CfDs.

- The payment from generator to government:

$$V_t = k_i g_t^{ref} p_t, \quad (8)$$

where g_t^{ref} is the reference generation profile (a normalized capacity factor), in MWh/MW. It is zero when the price is negative, hence V_t payments are suspended.

The annual revenue of a generator under a financial CfD is

$$R_{i,y}^{f-CfD} = \sum_{t=1}^{t=T} (M_{i,t} + F - V_t) = \sum_{t=1}^{t=T} (q_{i,t} p_t + k_i A - k_i g_t^{ref} p_t). \quad (9)$$

As contract factor α and contracted capacity k approach 0, such that $F = V_t = 0$, the revenue and risk profile of this contract converge to the merchant case. Conversely, for a generator whose production follows exactly the adjusted reference generation $q_{i,t} = k_i g_t^{ref}$, we have $M_{i,t} = V_t$ and the hourly income equals the fixed payment F , so revenues become completely independent of price and volume fluctuations. This highlights that the remaining source of risk under a financial CfD stems from deviations of actual production from the reference profile ("basis risk").¹

Two parameters need to be specified to define the contract: the contract factor α and the reference profile g_t^{ref} (A is, like S , determined by an auction). We use the national hourly capacity factor of onshore wind as the reference profile:

$$g_t^{ref} = \frac{Q_t^w}{K_t^w} \quad (10)$$

where K_t^w is the total installed capacity for onshore wind in Germany at time t .

By varying the way in which we set the contract factor, we model four specifications of the financial CfD. In contrast to our specifications for two- and one-sided CfDs, which affect both dispatch incentives and cash-flow risk, the financial CfD specifications only change the level of basis risk and do not affect

¹ As with all contracts that entail a payment from generator to government, this design does not imply the necessity that it is a subsidy. for a given value of $A = \frac{1}{T} \sum_{t=1}^T (g_t^{ref} P_t)$ the generator would perceive, on average, only its own market income $M_{i,t}$, making this contract revenue neutral while still smoothing (or not) the cash flow.

dispatch: under this contract, generators always have an incentive to stop producing at negative prices. We therefore focus on how policymakers might choose the contract factor α_i to shape risk and support.

In our results, we consider the following four specifications of the financial CfD:

- (i) Baseline ($\alpha_i = 1$): All parks use their full installed capacity as contracted capacity.
- (ii) Fleet-optimal ($\alpha_i = \alpha^* = 0.525$): All parks share a common contract factor chosen to minimize average investment cost (equivalently, average downside risk) across our sample; the calculation of α^* is described in Section A.2.
- (iii) Technology-adjusted: Contract factors are park-specific and proportional to expected production levels. We approximate technology differences by each park's average annual capacity factor over the first three years after installation and scale these relative to the national capacity factor, obtaining a park-specific factor α_i^{tech} . This specification aims to align fixed payments and claw-backs with expected production, thereby mitigating adverse selection concerns.
- (iv) Park optimal ($\alpha_i = \alpha_i^*$): Finally, we allow for park-specific optimal contracts, where α_i is chosen specifically to minimize the LCOE for each project. The optimization procedure is detailed in Section A.2.

A.2 Method

Measuring cash-flow risk

We assess the cash-flow risk that investors face under each contract design. Cash-flow risk is a standard concept in the corporate finance and financial distress literature. As discussed in Section 2.1, many studies measure it using the standard deviation of earnings normalized by average sales, that is, the coefficient of variation (CoV) of cash flow. We follow this literature and use the CoV of annual revenues across the sample period as a normalized measure of cash-flow risk for each wind park and contract.

The coefficient of variation (CV) is defined as

$$CV_i = \frac{\sigma(R_{i,y}^c)}{\mu(R_{i,y}^c)}, \quad (11)$$

where $R_{i,y}^c$ is the annual revenue in year y under contract c expressed in €/MW of installed capacity, $\sigma(\cdot)$ denotes the standard deviation, and $\mu(\cdot)$ is the mean of all years. Normalizing by average revenue allows us to compare risk across parks with different sizes and production profiles.

We simulate hourly revenues and aggregate them to the annual level before computing CoVs. Aggregation to annual revenues removes intra-year seasonality and focuses on the time horizon relevant for meeting debt service and other yearly obligations (Alcorta et al., 2024). We interpret each observed year as a distinct and equally likely state of the world, so the CoV summarizes the dispersion of revenues across these states. This provides a simple, comparable measure of overall cash-flow risk, which we complement with a project finance model focused on downside risk in the next subsection.

Financial model for downside risk

While the CoV is a measure of risk, policy makers and investors ultimately care about how such risk affects debt-to-equity ratios, the cost of capital, and LCOE. In project finance practice, lenders size debt based on low-percentile cash flows or minimum debt service coverage ratios (DSCRs), rather than on average volatility alone. In this spirit, we develop a stylized financial model that maps the simulated annual revenue distribution under each contract into feasible capital structures and implied financing costs (WACC). The purpose is to formalize a simple and transparent mechanism through which cash-flow risk affects those indicators.

Consider a representative wind project with a lifetime of $Y = 30$ years. Investment costs C^{fix} are incurred upfront, while annual operating and maintenance costs C^{om} are constant over time. Annual revenues $R_{i,y}$ are uncertain and depend on the spot market and the long-term contract, as described in Appendix A.1, with each observed year interpreted as an equally likely and independent state of the world within the context of this project finance model.

Project cash flows in each year are allocated in the following order:

1. Operating and maintenance costs, assumed to be fixed and paid with certainty;
2. debt service, consisting of a constant annual payment; and
3. equity payouts, the residual cash flow.

Projects are financed through debt and equity with fixed and exogenous returns of 1.15% and 10%, respectively (see Table 2). We assume no reserve accounts and no refinancing. Debt is modeled as a fixed annuity loan with maturity equal to the project lifetime. Let D denote total debt, and r_d the cost of debt. Annual debt service is given by:

$$DS = D \cdot \frac{r_d(1 + r_d)^Y}{(1 + r_d)^Y - 1}. \quad (12)$$

The solvency condition we impose is that debt service must be fully covered in every simulated year, i.e.,

$$R_{i,y}^c - C^{om} \geq DS \quad \forall y. \quad (13)$$

This corresponds to a DSCR of at least one in all states. While this assumption is stricter than some standard project finance benchmarks, it allows us to directly link revenue volatility to maximum feasible leverage in a transparent way. For a given contract design c and wind park i , this condition defines the maximum sustainable debt level $D_{i,c}^{max}$. Intuitively, contracts that raise the minimum annual cash flow permit higher leverage, which reduces WACC.

The remaining investment cost is financed with equity. Let total investment cost be $I_i = C^{fix} * K_i$. Equity is then $E_{i,c} = I_i - D_{i,c}^{max}$. Equity holders receive the residual cash flow after debt service and O&M. Their participation constraint requires the expected present value of dividends to cover the equity investment,

$$\sum_{y=1}^Y \frac{\mathbb{E}[\Pi_{i,c,y}]}{(1+r_e)^y} \geq E_{i,c}. \quad (14)$$

where $\Pi_{i,c,y}$ denotes annual dividends and r_e is the required return on equity. We assume equity holders bear the residual risk, so we evaluate their participation in expectation, in contrast to debt which is constrained by the worst realization.

In equilibrium, competitive auctions for support contracts imply that projects bid such that they just break even. For each wind park and contract design, we jointly determine:

- the maximum feasible debt level $D_{i,c}^{max}$,
- the implied equity requirement $E_{i,c}$, and
- the support level as defined by contract parameters (strike price or fixed payment)

such that both the debt solvency condition and the equity participation constraint are just binding. In other words, competition for contracts ensures that equity investors do not earn excessive profits. This yields an implied LCOE for each contract and project, reflecting both the distribution of annual cash flows from the contract and the endogenous financing structure. Contracts that reduce downside cash-flow risk allow projects to carry more debt, substituting cheaper debt for expensive equity, thus lower the weighted average cost of capital, and hence have a lower LCOE.

For financial CfDs, we apply the same procedure but, as discussed in Appendix A.1, in some specifications we also optimize over the contract factor α_i to study how different parameter choices affect leverage and LCOE. For the fleet-optimal specification we solve the model for common contract factors from 0.35 to 1.25 in steps of 0.025 and select the factor with the lowest average LCOE across the 63 parks ($\alpha^* = 0.525$). For the park-optimal specification we solve, for each park, for the fixed payment and contract factor combination that maximizes debt capacity subject to the break-even condition, which minimizes the cost of electricity.

A.3 Data

A key strength of the study is the use of real production data from operational turbines rather than simulated or synthetic profiles. Real output is shaped by constraints that are often unobserved or hard to model, so using realized feed-in lets us observe them directly and produce more realistic estimates of revenue volatility. The data also capture heterogeneity that simulations miss: not only weather and price years, but site quality and turbine technology.

The core dataset consists of turbine-level production records for 381 turbines, aggregated into 93 wind parks, in Germany. These turbines vary in size and age, with an average rated power of 2.1 MW; the oldest was commissioned in December 1995 and the newest in May 2024. To obtain a long, balanced panel, we exclude parks entering operation after 2014 and remove parks with missing or persistently very low production (below an hourly average of 0.06 MWh per MW of rated power). The resulting sample covers a ten-year period (2014–2023) over which all parks are continuously observed, and includes major market events such as the low prices of Covid-19 and the high prices of the 2022–2023 energy crisis, alongside a wide range of weather years. The final estimation sample contains 268 turbines across 63 parks with a combined capacity of about 510 MW.

The simulations use three additional time series: hourly electricity prices from the ENTSO-E Transparency Platform; potential-generation feed-in profiles from Netztransparenz, used to build the national hourly production profile for financial CfDs; and installed capacity from Open Power System Data and ENTSO-E, used to normalize feed-in into capacity factors.

Although uniquely detailed, all assets are operated by a single company and are geographically concentrated in north-eastern Germany. Figure A1 shows the location, commissioning year, and installed capacity of the 63 parks, highlighting both regional clustering and heterogeneity in turbine vintages.




Figure A1. Location, commissioning year (color), and installed capacity (marker size) of the wind parks in the sample.

To gauge representativeness, we compare each park's hourly normalized production profile with the national onshore-wind profile. Correlations range from about 0.3 to 0.8, with a mean near 0.6 (Figure A2), which indicates substantial diversity in production patterns. Figure A3 shows how the sample sits against the market value of onshore wind over the period. Most parks earn slightly less per MWh than the national average. Four earn more: two by less than 2 €/MWh and two by about 17 and 20 €/MWh. The sample therefore includes both kinds of project, though not in equal numbers, and the results in Section 4.2 should be read with that in mind. We regard this heterogeneity as representative of a history of projects being built with production-based support contracts, yet informative of real-world investment opportunities.




Figure A2. Histogram of correlations between each park's hourly normalized output and the national onshore-wind profile; the vertical line marks the sample mean.




Figure A3. Distribution of capture prices across the 63 wind parks, measured as merchant revenue per MWh of potential output over 2014–2023. The dashed line marks the market value of onshore wind over the same period (56.9 €/MWh), computed on the national feed-in profile under the same assumption about negative-price hours. Four parks lie above it.

For each turbine we observe hourly power feed-in, on-site wind speed, and a log of outages with cause and duration (grid constraints, maintenance, permitting, marketing decisions), including both full and partial curtailment. On average, turbines produce about 91% of their potential output, with roughly 9% curtailed for operational or grid-related reasons, and grid-induced curtailment accounts for the largest single share (Figure A4).




Figure A4. Distribution of lost generation (as a share of potential output) by outage category. Bars show the average curtailed generation for each cause; whiskers indicate the central 90% (5–95%) of the distribution.

In Germany, energy curtailed for grid reasons is typically compensated as if it had been delivered, since such constraints are outside investors' control. To keep parks comparable and to match this compensation regime, all simulated revenue streams are based on potential generation, that is, the output that would have occurred without grid-related curtailment, while retaining other causes of curtailment.

Appendix B. Robustness

The financial model applies current, homogeneous investment and operating costs to all projects, even though the sample spans almost two decades of vintages, site qualities, and contractual arrangements. In Germany in particular, land leases (the major component of O&M costs) are often linked to realized revenues rather than fixed in advance, which would require more granular cost modeling. Because project-level cost structures cannot be mapped to each turbine, we use a common benchmark, trading realism for transparency and comparability, and test its influence with a sensitivity analysis. Figure B1 shows the average LCOE reduction across a wide range of investment and O&M costs, for the best-performing specification of each design.




Figure B1. Average reduction in LCOE across wind parks as a function of assumed investment cost and operating-and-maintenance cost. The square highlighted in orange marks the baseline assumptions.

The ordering of contracts is essentially unchanged across the parameter space. Two-sided and fleet-optimal financial CfDs deliver very similar reductions, while the park-optimal financial CfD dominates at every grid point. Reductions are largest where investment costs are high and operating costs low, as expected, and smallest in the opposite corner. In short, while the exact magnitude of the risk-reduction effect is sensitive to cost assumptions, the relative ranking of contracts is robust.

Appendix C. Additional results

Contract	Clearing bid	Average bid	Average rent	Net support – own bid	Net support – marginal bid	Total rent, €/a
Financial CfD (park-optimal)	67.06	56.11	10.95	2.15	13.10	4.02 M
Two-sided CfD (annual)	71.94	59.29	12.65	5.33	17.98	4.65 M
One-sided CfD (annual)	77.67	67.88	9.80	13.93	23.73	3.68 M
Financial CfD ($\alpha = 1$)	79.19	59.78	19.41	5.52	24.93	7.57 M

Table C1. Public cost under the two auction payment rules, at a procurement volume of twenty projects. Each project bids the support level at which it just breaks even. Under pay-as-bid every winner receives its own bid; under a uniform clearing price all winners receive the bid of the marginal winner, and the difference accrues to the infra-marginal projects as rent. Columns three to six are energy-weighted averages over the winning set, in euros per MWh; column two is the marginal winner's own bid. The last column converts the rent into an annual total for the volume procured. The rent is largest under the financial CfD with a contract factor of one, whose bids are the most widely dispersed, which is enough to make it the most expensive of the four designs under uniform pricing although it is not under pay-as-bid.



Ariadne's thread through the energy transition: The Kopernikus project Ariadne leads the way in a joint learning process with representatives from politics, business and society, exploring options for shaping the energy transition and providing scientific guidance to policy makers along the pathway towards a climate-neutral Germany.

Follow Ariadne's thread:



@ariadneprojekt.bsky.social



Kopernikus-Projekt Ariadne



ariadneprojekt.de

More about the Kopernikus projects from the BMFTR at kopernikus-projekte.de/en/

Who is Ariadne? In Greek mythology, Ariadne's thread enabled the legendary hero Theseus to safely navigate the labyrinth of the Minotaur. This is the guiding principle of the Ariadne energy transition project, in which a consortium of 25 partners is providing guidance and orientation for shaping the energy transition through excellent research as a joint learning process between science, politics, business and society.

We are Ariadne:

adelphi | Brandenburg University of Technology Cottbus-Senftenberg (BTU) | German Institute for Economic Research (DIW) | German Aerospace Center (DLR) | Ecologic Institute | Research Institute for Sustainability Helmholtz Centre Potsdam (RIFS) | Fraunhofer Cluster of Excellence Integrated Energy Systems (CINES) | Hertie School | ifo Institute – Leibniz Institute for Economic Research at the University of Munich | German Economic Institute | Julius-Maximilians-Universität Würzburg | Öko-Institut | Potsdam Institute for Climate Impact Research (PIK) | Leibniz Institute for Economic Research | Stiftung Umweltenergierecht | German Institute for International and Security Affairs | Technische Universität Berlin | Technical University of Darmstadt | Technical University of Munich | University of Duisburg-Essen | University of Greifswald | Universität Hamburg | University of Potsdam | University of Stuttgart – Institute of Energy Economics and Rational Energy Use (IER) | ZEW – Leibniz Centre for European Economic Research